

33-1 GENERAL

- A. EXTENT OF WORK of this Division:
Caulking of joints around window and door frames and other openings in exterior masonry and concrete walls, except as called for under other divisions. Caulk other spaces noted on drawings and as required to make weather tight.

33-2 MATERIALS

- A. CAULKING COMPOUND
Farwest Paint's "Elasto-Seal," Kuhl's "Elastic," Pacific Putty's "Perma-Seal," or approved.
- B. CONSISTENCY & COLOR OF CAULKING COMPOUNDS
Gun consistency, color to match adjacent surfaces, unless directed otherwise.
- C. CAULKING PRIMER
Made or recommended by manufacturer of the caulking compound.
- D. ROPE YARN
Raveled strands of non-staining fiber or cotton wicking.

33-3 WORKMANSHIP

- A. PREPARATION
See that joints and spaces to be caulked are clean and dry.
Prime unpainted surfaces before caulking.
Where joints are more than 3/4 inch deep, or where no suitable backstop is provided, pack with rope yarn to within 1/2 inch of surface.
- B. CAULKING
Caulk joints before final coat of paint is applied.
Apply compound with gun having nozzle of proper size.
Use sufficient pressure to fill joints and voids solid.
Superficial pointing with skin bead not accepted.
Remove excess compound and leave surfaces neat, smooth and clean.

END OF DIVISION 33